

PB fittings

Product specification

The products mentioned below belong to this certificate

General

Fittings of PB intended for the transport of cold and heated drinking water according to BRL-K 536, part C.

Detailed specification

The diameters and wall thicknesses indicated in the table below, belong to this product certificate.

Nominal outside diameter (mm)	Wall thickness (mm)
15	1,7
16	1,8
20	2,3
22	2,0
22	2,4
25	2,3
28	2,5
32	2,9
40	3,7
50	4,6

The fittings make use of an insert system.

Colour: Grey

Toxicological requirements

Approval:

This product is approved on the basis of the requirements set in the "Regeling materialen en chemicaliën leidingwatervoorziening" ("Regulation Materials and Chemicals for Drinking Water Supplies"; published in the Staatscourant).

ATA criteria:

The ATA product certification is based on two main criteria. It should permanently comply with:

- The product recipe approved during the assessment procedure. The recipe is laid down in the for confidentiality reasons undisclosed appendix 1A to the certification agreement K24321/03. This recipe is not to be changed without prior approval by Kiwa according to the Kiwa-ATA-approval procedure;
- Specific ATA-product requirements, laid down in appendix 1A to the certification agreement K24321/03. For confidentiality reasons this appendix 1A is not public.

Logistics

Production and assembly of the system are laid down in the annex(es) of the product certification agreement(s).

Marking

The products are marked with the Kiwa-mark.

The **PB fittings** are provided with at least the following marks:

- * manufacturer's name, trade name or logo;
- * nominal outside diameter in mm of the connecting pipe;
- * production code.